

CERTIFICATE

The company

EUROTERM d.o.o

Lece Koteski 05
7500 PRILEP
MACEDONIA

with the production site in

Prilep

hereby receives the confirmation that the product/s

Solar collectors

of the type

ESK 2.5 SB

conforms to

DIN EN 12975-1:2006-06
DIN EN 12975-2:2006-06

Specific CEN KEYMARK Scheme Rules for Solar Thermal Products version 11.04 (Edition: 2009-12)

and is granted the licence to use the marks



in conjunction with the Registration No. below.

Registration No.: 011-7S1250 F

This Certificate is valid until 2015-06-30.



DGA-ZE-2460.99

See annex for further information.

DIN CERTCO Gesellschaft für
Konformitätsbewertung mbH
Alboinstraße 56, 12103 Berlin



2010-06-04

Dipl.-Ing. Dipl.-Wi.-Ing. Sören Scholz
- Head of Certification Body -



Annex

to the Certificate with Registration No. 011-7S1250 F, dated 2010-06-04

Technical data

See data sheet, part of the test report of 2010-06-01

Note(s):

- The freeze resistance test according to DIN EN 12975-2, clause 5.8 was not necessary.
According to the manufacturer's declaration, the certified solar collectors may be used in frost exposed areas only in combination with appropriate frost protection mixtures.
- The optional impact resistance test according to DIN EN 12975-2, clause 5.10 was not carried out.

Testing laboratory / Inspection body

Institut für Solartechnik SPF
Hochschule für Technik
Rapperswil
Oberseestrasse 10
8640 RAPPERSWIL
SCHWEIZ

Test report(s)

No. C1192LPEN, No. C1192QPEN dated 2010-01-06

6/5